


**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE**


No. 375-----


Date : 18 / 11 / 2022

It is certified that an inspection team headed by **Abrarul Haque, A.E. (P.H.E.D)** from **P.H. Division, Forbesganj** inspected the **AL- FAIZ MODEL ACADEMY, BASMATIYA, NARPATGANJ-09, ARARIA** on Dated **15/11/2022** and found that the **AL- FAIZ MODEL ACADEMY, BASMATIYA, NARPATGANJ-09, ARARIA** has Safe Drinking Water Facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the State Government.

The above is valid for - **One year**

  
Assistant Engineer  
P.H.Division, Forbesganj.

  
18/11/22  
Assistant Engineer  
P.H.Division Araria.

Signature With Seal :   
Name :-- Er. Abrarul Haque --  
Designation :-- Assistant Engineer --  
P.H.Division Forbesganj.

Letter No. 363 Dated: 18/11/2022

## Government of Bihar

### DISTRICT LEVEL WATER TESTING LABORATORY UNDER, PUBLIC HEALTH DIVISION ARARIA. CHEMICAL AND BACTERIOLOGICAL REPORT OF DRINKING WATER SAMPLES


District Name: -- ARARIA


Month - NOVEMBER - 2022

SL. No.	Location of Source	Parameters Examined														Remarks	
		pH	Turbidity	Conductivity	TDS	Total Hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic		Bacteria
1	Al Faiz Model Academy, Basmatiya, Narpatganj-09, Araria.	7.3	0.4	210	137	98	17.6	13.12	38	70	0.31	5.0	10	-	-	-Ve	Acceptable
	Desirable Limit*	6.5-8.5	1.0	-	500	200	75	30	250	200	1.0	45	200	1.0	0.01	-	
	Permissible Limit* in absence of alternate source	NR	5.0	-	2000	600	200	100	1000	600	NR	NR	400	1.5	NR	**	

Note - (i) Drinking Water Specification Second Revision -IS: 10500-2012., (ii) BDL means Below Detection Limit., (iii) NR means no relaxation and (iv)\*\* Shall not be detectable in any 100ml sample

  
18/11/2022  
Lab. Assistant  
P.H.Division, Araria.

  
18/11/2022  
Chemist (Lab Incharge)  
P.H.Division, Araria.

  
18/11/22  
Assistant Engineer  
P.H.Sub.Division, Araria West

  
Executive Engineer  
P.H.Division, Araria.